

Questions and Answers – Construction Materials Solicitation # SBG30016Q0198 (PR4904021)

Dear Prospective Offeror,

Please see answers in response to the questions received from the following contractor on the subject solicitation:

Questions from ManTech Engineering Lss:

Question # 1: The sandwich panel will use cold room or warehouse purpose.

Answer: Air conditioned general purpose room roof & work shop roof.

Question # 2: The actual cold room warehouse building size (L X W X H) . Because of we need sandwich panel width Size.

Answer: 42 to 45 inch width required.

Question # 3: Which type of sandwich panel are require PU or XPS?

Answer: Please quote for both and explain purpose of use PU or XPS.

Question # 4. How much EPS Density are required such as 20KG/M3 or 40KG/M3?

Answer: 20kg/m3

Question # 5: How much thickness are require sandwich panel sheet thickness such as 0.45mm PPGI Sheet?

Answer: 47mm

Question # 6: How much thickness are require for " L " cap?

Answer: 2mm

Question # 7: How much thickness are require MS Hollow box and U channel ?

Answer: 2mm

Thanks and regards, Shahana Begum

Contracting Specialist
Procurement and Contracting Section
American Embassy, Dhaka, Bangladesh